

Certificate of Completion

Duct Sealing Performed for:

Overall Sealing Results

When we arrived,
YOUR DUCTS HAD:

548 CFM of Leakage, equivalent to a
104 Square Inch Hole


After we finished,
YOUR DUCTS HAVE:

33 CFM of Leakage, equivalent to a
6 Square Inch Hole

This corresponds to a **94%
Reduction** in Duct Leakage

Note: Duct leakage results are calculated in cubic feet per minute (CFM) measured at a standard reference pressure of 25 pa (0.10 in. water).

Aerosol Sealing Profile



**Your Heating and Cooling Capacity
Improvement for Duct Sealing is
23%
based upon measured leakage
reduction and original register flow**

Aeroseal Equipment Serial #: 1005
Monday, March 07, 2011